



Government Of West Bengal  
Office Of The Director General  
West Bengal Fire & Emergency Services  
13D, Mirza Ghalib Street, Kolkata - 16

Memo  
no.:WBFES/2139/17/Kol/EB/676/16(676/16)

Date: 27-08-2021

From:  
Director  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services

To: DAV PUBLIC SCHOOL, BARRACKPORE  
Ruiya, Barrackpore, West Bengal 700119

Sub: Fire Safety Certificate for the occupancy of a Semi Basement + G + III storied Educational building under group Educational building in the name and style of "DAV PUBLIC SCHOOL, BARRACKPORE" AT the premises no. J.L No. -20 , Mouza-Ruiya, P.S- Khardha, Dist-24 pgs(N), Barrackpore, West Bengal, Kolkata- 700119.

This is in reference to your application no. 0125189211100275 dated 09-08-2021 regarding the Fire Safety Certificate for the occupancy of a Semi Basement + G + III storied Educational building under group Educational building in the name and style of "DAV PUBLIC SCHOOL, BARRACKPORE" AT the premises no. J.L No. -20 , Mouza-Ruiya, P.S- Khardha, Dist-24 pgs(N), Barrackpore, West Bengal, Kolkata- 700119.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

The Fire Safety audit to be conducted at three (03) months interval and to be recorded in the Fire Prevention maintenance register and also a copy of audit report shall have to be submitted at local Fire Station.

- 1.As per NBC & Fire Safety measure maintained and comply as per rule.
- 2.Fire pump and Detection system always to be kept in auto mode condition.
- 3.Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
- 4.The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189211100275.

Page : 1

  
Principal

D.A.V. Public School Barrackpore

  
MANAGER  
D.A.V. Public School Barrackpore

Powered By  For secure paperless solutions  
Please visit [www.emsigner.com](http://www.emsigner.com)

  
Chairman  
D.A.V Public School, Barrackpore

Specification.

- 5.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
- 6.Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
- 7.A Fire control room including a closed circuit TV system shall have to be maintained which observe all the floors of the building.
- 8.The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Buildings.
- 9.The employees and security staff shall be conversant with installed fire fighting equipment's of the buildings and to operate in the event of fire and testing.
- 10.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
- 11.Switch gear shall be protected with automatic CO2 or DCP Fire extinguishers confirming I.S. specifications.
- 12.A trained Fireman shall be maintained round the clock for fire safety of the building.
- 13.First Aid fire fighting system shall be provided as per I.S. specifications.
- 14.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Buildings to keep them in perfectly good working condition at all the times.
- 15.If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 16.Electrical Ducts shall have to be sealed vertically and horizontally in proper manner immediately.
- 17.Periodical flashing of water in the Hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
- 18.The fire check door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.
- 19.The Fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
- 20.As per Fire Safety Recommendation and NBC part IV observes all the floors of the building maintains all rules & regularities, otherwise it should be treated as cancel FSR.
- 21.This Fire Safety Certificate is valid for 03 (Three) years and has to be renewed within stipulated period from the date of issuance of this letter, from the Director General, West Bengal Fire &Emergency Services regarding performance of all the

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189211100275.

Page : 2

  
Principal  
D.A.V. Public School Barrackpore

  
MANAGER  
D.A.V. Public School Barrackpore

Powered By  For secure paperless solutions  
Please visit [www.emsigner.com](http://www.emsigner.com)  
  
Chairman  
D.A.V. Public School, Barrackpore



Fire Safety arrangements and installations of the building.

Signature valid

Digitally signed by ABHIJIT  
PANDEY  
Date: 2021.09.27 16:21:16 IST

Director  
West Bengal Fire & Emergency Services

**Principal**  
**D. A. V. Public School Barrackpore**

**MANAGER**  
**D.A.V. Public School Barrackpore**

**Chairman**  
**D.A.V. Public School, Barrackpore**

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189211100275.

Page : 3