



**Government of West Bengal**  
**Office of the Director General**  
**West Bengal Fire & Emergency Services**  
**13D, Mirza Ghalib Street, Kolkata – 16**

**Memo No.: FSR/WBFES/2139/17/Kol/EB/676/16(676/16)**

**Date : 02-07-2025**

**From :**  
**Divisional Fire Officer**  
**Fire Prevention Wing,**  
**West Bengal Fire & Emergency Services**

**To :**  
**DAV PUBLIC SCHOOL, BARRACKPORE**  
**Ruiya, Barrackpore, West Bengal 700119**

**Memo No.:**

**Sub : Renewal Fire Safety Certificate of an existing construction of Semi Basement+G+I storied school building Under group of Education building in the name and style " DAV Public school, Barrackpore" " at the premises no. J.L no-20, Mouza- Ruiya, P.S.- Kharda, Dist-24 Pgs(N), Barrackpore , West Bengal,, Kolkata-700119.**

This is in reference to your AIN 211912506300004268 dated 11-Mar-2025 regarding Renewal Fire Safety Certificate of an existing construction of Semi Basement+G+I storied school building Under group of Education building in the name and style " DAV Public school, Barrackpore" " at the premises no. J.L no-20, Mouza- Ruiya, P.S.- Kharda, Dist-24 Pgs(N), Barrackpore , West Bengal,, Kolkata-700119..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

**However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.**

**Recommendation:**

CONDITION : STANDBY FIRE PUMP SHALL HAVE TO BE INSTALLED.

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.



The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300004268

2. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building shall be strictly maintained.
3. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in there, particularly lines above false ceiling & ducts.
4. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all vulnerable of the building.
5. Regular Mock fire Practices and evacuation drill should be conducted periodically by participation of all the occupants of the building and for this purpose a special crew should be formed.
6. A Crew of trained fire man should be maintained round the clock for the safety of the building.
7. Arrangement shall have to make for regular checking and testing of the fire fighting system in the building to keep the system in good working condition.
8. Periodical flashing of water in the Hydrant shall be made to maintain the efficiency of the above mentioned system.
9. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
10. The Fire Check Door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.
11. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
12. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
14. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
15. The Fire Safety Audit to be conducted at in a regular interval and to record in the Fire Prevention Maintenance register.
16. This Renewal of Fire Safety Certificate is valid for three (03) years and has to be renewed within stipulated period from the date of issue of this certificate from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Valid Upto : 30-Jun-2028



**Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912506300004268